City of Winter Park Fire-Rescue Department
343 West Canton Avenue~ Winter Park, Florida 32789

COOKING/WARMING/SERVING FOOD APPLICATION

THIS DOES NOT INCLUDE FOOD TRUCKS

1. The gas cylinder shall be properly secured from being knocked over.
2. **Butane operated appliances are strictly prohibited**.
3. If deep fat frying there shall be a Florida certified K Class extinguisher within 20 feet of the appliance(s).
4. There shall be at least a 16 inch vertical or horizontal separation from the deep fat fryer and any other cooking appliance.
5. There shall be a Florida certified 2A 10BC extinguisher within 75 feet of the cooking operation.
6. There shall be at least a 10 foot radius from all other tents, structures or public access from all of the cooking appliances and the gas cylinders.
7. This shall be completed and submitted by each individual vendor at the event.

ANY NON-COMPLIANCE WITH ANY OF THE ABOVE WILL BE CAUSE FOR THE OFFICE OF THE FIRE MARHSAL TO IMMEDIATELY STOP ALL OPERATIONS UNTIL FULL COMPLIANCE. IF ENFORCEMENT IS REQUIRED AFTER NORMAL WORKING HOURS, THE AFTER HOUR FIRE INSPECTION FEES WILL APPLY.

I have read and will comply with the requirements as listed above.

_____ _____

Company Name *Contact Name*

_____

Address *City* *State* *Zip*

_____

Signature

_____ _____

Date of event *Date signed*

_____

E-Mail address