

9/29/2023

Winter Park Public Safety Facility

ASHRAE Level II Energy Audit



15 lightyears

Energy Testing | Solar Power | Green Certification



Table of Contents

| | |
|---|----|
| Executive Summary..... | 3 |
| Project Information & Contacts | 3 |
| General Facility Description | 4 |
| Mechanical Systems..... | 4 |
| Building Controls..... | 5 |
| Lighting Systems | 6 |
| Domestic Water Fixture (Plumbing) Systems | 6 |
| Building Envelope..... | 6 |
| Key Operating Parameters..... | 6 |
| Site Visit | 6 |
| Utility Analysis..... | 6 |
| Historical Utility Data | 6 |
| Benchmarking | 8 |
| Utility Rate Analysis | 8 |
| Average Rates | 9 |
| Energy Saving Opportunities..... | 10 |
| Chiller Optimization | 10 |
| DX CRAC Unit Retrofit | 11 |
| CV to VAV | 12 |
| AHU Controls..... | 13 |
| Controls Optimization | 13 |
| Lighting Improvements | 14 |
| Facility Improvement Measures – Code Compliance | 14 |
| DHW Retrofit..... | 14 |
| Calculation Methodology – Spreadsheet System Models | 15 |
| Chiller Optimization | 15 |
| DX Unit Retrofits | 15 |
| CV to VAV | 16 |
| AHU Controls..... | 16 |
| Controls Optimization | 17 |
| Lighting Improvements | 17 |
| Appendix A – Lighting Line by Line | 19 |

Appendix B – Mechanical Equipment 21
Appendix C – Site Walkthrough Photos 25

Executive Summary

TLC Engineering Solutions (TLC) performed an ASHRAE Level 2 facility energy audit of the Winter Park Public Safety Building as a part of its contract with the City of Winter Park.

This report is related to the energy-consuming systems only and is intended to fulfill the requirements of an ASHRAE Level 2 Energy Audit, per the guidelines set forth by the ASHRAE document “Procedures for Commercial Building Energy Audits.” The purpose was to observe existing conditions and gather information that would enable TLC to render an opinion concerning conditions or deficiencies that could affect efficient use of this facility, and to identify potential areas for improvement. Neither the field visits nor this report is intended to uncover hidden defects or the presence of hazardous materials.

TLC reviewed the as-built design drawings dated April 7, 2003, current utility bills from January 2021 through June 2023, subsequent project documentation, and visited the site in January 2023 to review the mechanical and electrical equipment, the HVAC and lighting controls systems, and observe each space type and its general energy use intensity. During this time, TLC was granted access to the building automation system to view the operation remotely. In the course of its work, TLC obtained extensive photo documentation of the conditions of the facility. Several of the photographs are included in Appendix C of this report, and the reader is encouraged to thoroughly review the photographs and descriptions, as they are intended to support and supplement the observations described herein.

After the time on site, TLC developed energy saving spreadsheets to assist with the analysis of recommended Energy Conservation Measures (ECMs), Facility Improvement Measures (FIMs), and evaluated BAS trends. The combination of all the walkthrough and post-walkthrough activities led to the development of the ECM and FIM list. A complete description and analysis of each ECM, as well as a table summarizing estimated cost and savings of each measure, can be found later in this report in the Energy Saving Opportunities section.

Project Information & Contacts

ASHRAE Level II Audit of the Winter Park Public Safety Building
500 N Virginia Ave, Winter Park, FL 32789

Gloria Eby

Natural Resources and Sustainability Director
geby@cityofwinterpark.org
Office: 407.599.3471

Lisa Pearcy

CEO, 15 Lightyears
lpearcy@15lightyears.com
Office: 855.438.1515

Eric McEwen

Principal, TLC Engineering Solutions
eric.mcewen@tlc-eng.com
Office: 407-487-1240
Cell: 904-635-0129

General Facility Description

The Winter Park Public Safety Building is a two-story civic building of approximately 35,000 square feet, which includes a police station and fire station, as well as support facilities for each. An aerial view of the Public Safety Building is shown below.




Figure 1: Aerial View of the Winter Park Public Safety Building

The first level of the building houses the reception area as well as offices, conference spaces, evidence lockers, holding cells, training spaces, etc. The second level includes additional office, conference, and support spaces.


Mechanical Systems

The Winter Park Library features mechanical systems mostly dating to the original design in 2002. Overall, the building utilizes Air Handling Units, an Air-Cooled Chiller, CRAC Units, VAV Terminal Units, and Exhaust Fans. Mechanical system information came from a combination of resources, including information gathered during TLC’s audit walk-through of the building and building automation system review, as-built design drawings provided by the City of Winter Park (dated April 7, 2003). The below breakdown of the

mechanical systems and areas they serve is TLC’s best attempt to consolidate all avenues of information into one master list.

Equipment Naming Convention

The general naming convention used on the mechanical drawings is shown below. Please note, this convention applies to most of the equipment, but not all equipment.



Air Handling Units

Air conditioning for the majority of the building is provided by four (4) chilled water air handling units. Each unit serves a dedicated area of the floor plate on a single floor. AHU-4 is located on the roof and provides conditioning for the vehicle evidence area. The units are equipped with a variable frequency drive (VFD) to allow supply air to modulate based on changing load conditions, as well as modulating chilled water control valves to control cooling capacity. Areas served by the AHUs reception areas, training rooms, holding cells, etc.

Air-Cooled Chiller

The building HVAC systems are supplied with cooling capacity via an air-cooled chiller, located to the rear of the building in the parking lot. The chiller includes two refrigeration circuits and VFD-controlled condenser fans to modulate chilled water capacity required to accommodate building load. The chiller is controlled via the building automation system to ensure that the air handling units receive the proper chilled water flow.

CRAC (Computer Room Air Conditioning) Units

Areas of the building that are not conditioned via the air handling units are provided with conditioning via DX CRAC Units. This includes communications spaces and 911 dispatch equipment spaces. There are four (4) DX systems manufactured by Liebert and Trane located in the Public Safety Building.

VAV Terminal Units

Variable Air Volume (VAV) boxes are duct devices that modulate flow to different thermal zones based on changing loads. The VAVs are part of the ductwork distribution from the AHUs and serve the various meeting rooms, offices, and training areas throughout the building.

Exhaust Fans

Exhaust fans were observed on the rooftop, providing general exhaust for restrooms located within the building. Additionally, specialized spaces such as evidence and equipment storage, among others, are provided with exhaust via dedicated fans.

Building Controls

The building is currently controlled by a centralized Building Automation System (BAS) utilizing Direct Digital Controls (DDC). The BAS allows for monitoring, scheduling and setpoint adjustment of the different HVAC systems. The BAS is a Trane Tracer Ensemble system with graphics for the major pieces of equipment. It was observed during the onsite audits that exhaust fans are manually set to run at all times.

Lighting Systems

Interior lighting throughout the facility is predominantly linear fluorescent fixtures utilizing T8 lamps. The lighting is controlled manually with no occupancy controls.

Domestic Water Fixture (Plumbing) Systems

The building is served by three (3) natural gas-fired water heaters, and one electric water heater. The water heaters are located in designated water heater rooms along with the hot water recirculation pump for the building. Each water heater has 80-gallon storage capacity with 150 kBTU/hr heating capacity.

Building Envelope

The building envelope systems date to the original 2002 construction of this facility. The façade is stucco over tilt-up concrete panels. All facades have original historic operable windows. The facility includes glazing designated as impact-resistant. The roof is a flat, built-up roof construction. TLC noted that the roof membrane was in the process of being replaced at the time of observation, with new TPO being installed.

Key Operating Parameters

The building is currently operated 24/7 due to the nature of the building mission. There are some areas that will experience typical office hours, but these areas do not currently have any controls schedule or temperature setbacks.

Site Visit

The site was audited by TLC engineers in January 2023. A full evaluation of existing energy consuming systems, compliant with ASHRAE Standard 211-2019 was performed. During the audit, TLC personnel were escorted by the City of Winter Park Facilities manager, Leif Bouffard. He, as well as any facility staff that were available for comment, were questioned on system operation, condition, and maintenance of the building systems.

Utility Analysis

Historical Utility Data

The building is currently served by electricity and water utilities by the City of Winter Park (CoWP). Electrical utility consumption and demand values were provided for the months of January 2021 through June 2023. The monthly consumption profile is as expected, where values increase in the warmer months due to cooling needs. No specific utility bills were provided, but a blended rate for kWh savings was determined based on the published rates for consumption and demand. Calculation of the blended utility rate takes into account the non-fixed costs associated with electrical utilities use by the facility, including fuel charges, per-kWh cost, demand charges, etc. Table 3 details the components of the blended rate calculation.

Public Safety Building – ASHRAE Level 2 Audit

Table 1: Annual Baseline Energy Consumption

| Utility | Total |
|-------------------------------------|-----------|
| Annual Electrical Consumption (kWh) | 1,577,129 |
| Annual Electrical Cost | - |

The following graph and table show the total consumption and demand per monthly billing period for electricity.




Figure 2: Public Safety Electric Consumption

Table 2: Public Safety Electricity Consumption Data

| Date | Consumption (kWh) | Demand (kW) |
|--------|-------------------|-------------|
| Jan-21 | 109,358 | 447 |
| Feb-21 | 104,285 | 474 |
| Mar-21 | 115,129 | 476 |
| Apr-21 | 108,195 | 502 |
| May-21 | 136,926 | 561 |
| Jun-21 | 133,511 | 588 |
| Jul-21 | 132,528 | 606 |
| Aug-21 | 142,712 | 299 |
| Sep-21 | 154,074 | 348 |
| Oct-21 | 130,257 | 262 |
| Nov-21 | 116,409 | 262 |
| Dec-21 | 100,783 | 262 |
| Jan-22 | 102,993 | 262 |
| Feb-22 | 110,588 | 262 |
| Mar-22 | 113,338 | 262 |
| Apr-22 | 104,085 | 262 |

| Date | Consumption (kWh) | Demand (kW) |
|--------|-------------------|-------------|
| May-22 | 116,967 | 262 |
| Jun-22 | 148,083 | 289 |
| Jul-22 | 164,676 | 307 |
| Aug-22 | 175,787 | 0 |
| Sep-22 | 152,291 | 717.4 |
| Oct-22 | 130,131 | 358.7 |
| Nov-22 | 134,570 | 358.7 |
| Dec-22 | 141,209 | 358.7 |
| Jan-23 | 147,950 | 358.7 |
| Feb-23 | 136,065 | 358.7 |
| Mar-23 | 122,705 | 358.7 |
| Apr-23 | 134,595 | 358.7 |
| May-23 | 122,422 | 358.7 |
| Jun-23 | 151,052 | 402.9 |

Benchmarking

TLC compared energy consumption utilizing a common benchmark to gauge how the building compares to similar ones nationally. The main means of comparison is the Energy Use Intensity (EUI), which is used by energy engineers to determine overall energy consumption to a common unit of measure. The Energy Use Intensity measures annual consumption of electricity per square foot, in kBTU/sf/year.

This common benchmark for energy usage is nationally recognized. Using the utility billing information, performing energy analysis and observing the system operation allows the energy profiles to be broken down to greater detail. The facility was entered into Energy Star Portfolio Manager as a Police/Fire Station.

Based on most recent 24 months of utility data, a comparison can be drawn between the Public Safety Building and the average energy use intensity (EUI) of similar buildings throughout the United States. The median EUI for a police/fire station in the United States is 63.5 kBTU/sf, and the calculated EUI of the Public Safety Building is 146.3 kBTU/sf. It is worth noting that the median value reported by Energy Star is dependent on the annual responses from building surveys, and that the capabilities present in police and fire stations can vary wildly by jurisdiction and location. Additionally, the building’s geographical location necessitates increased operation of HVAC systems, which are the largest consumers of energy nationwide. For these reasons, while the comparison is valuable, it can be difficult to draw specific conclusions based only on the median EUI.

Utility Rate Analysis

The building is provided with electricity by the City of Winter Park (CoWP), following their Rate Schedule GSD-1, General Service – Demand. The utility rate charges shown below were used to calculate the costs associated with the provided consumption and demand. Energy savings calculated for this building have been assigned a blended rate of \$0.1011/kWh, which is the calculated blended rate not including fixed customer charges.

Table 3: Utility Rate Schedule

| Description | Charge |
|--------------------------------------|---------------------------------|
| Demand Charge | \$5.05 per kW of billing demand |
| Energy Charge | \$0.04216 per kWh |
| Fuel Cost Recovery Factor | \$0.02281 per kWh |
| Gross Receipts Tax | 2.5641% |
| Franchise Fee | 6.00% |
| Electric Utility Tax | 10.00% |
| EL State Sales Tax (Commercial Only) | 7.45% (First \$5,000) |
| EL State Sales Tax (Commercial Only) | 6.95% (Over \$5,000) |

Average Rates

As noted above, a blended cost per kWh has been calculated from the rate schedule. Savings for this building have been calculated using the blended rate. The following table details the average rate over the period of analysis.

Table 4: Average Utility Rate

| Utility | Average |
|-------------|--------------|
| Electricity | \$0.1011/kWh |

Energy Saving Opportunities

The operation and condition of equipment at the Public Safety building was observed to offer a few different avenues for improvement. This is to be expected given the age of the equipment itself and how long it has been in service. Improvements can be made by replacing the aging equipment as well as optimizing the control sequences and settings. The following table summarizes the recommended ECMs for this facility that should be considered for future projects. In addition, the table distinguishes between measures specifically intended to save energy (ECMs) and facility improvement measures (FIM) that benefit the overall operation of the facility but may not provide significant energy savings.

Table 5: ECM/FIM Summary

| Energy Savings Measure | FIM/ECM | ECM Category | Annual kWh Savings | Annual \$ Savings | Cost \$ | Payback (years) |
|-------------------------------|---------|---------------------|--------------------|-------------------|-----------------|-----------------|
| E1 - Chiller Optimization | ECM | No Cost | 9,710 | \$982 | \$0 | -- |
| E2 – AHU-4 CV to VAV | ECM | Moderate Cost | 4,703 | \$475 | \$7,200 | 15.1 |
| 2a: Humidity Sensor | ECM | Low Cost | -- | -- | \$1,200 | -- |
| 2b: VFD Addition | ECM | Low Cost | -- | -- | \$3,000 | -- |
| 2c: Controls VAV Programming | ECM | Moderate Cost | -- | -- | \$3,000 | -- |
| E3 - AHU Controls | ECM | Low Cost | 22,733 | \$2,298 | \$5,990 | 2.6 |
| E4 - Controls Optimization | | Low Cost | 2,658 | \$269 | \$6,000 | 22.3 |
| E5 - Lighting Improvements | ECM | High Cost | 128,019 | \$12,943 | \$62,400 | 4.8 |
| F1 – DX Unit Retrofits (AC-2) | FIM | Capital Improvement | -- | -- | \$90,000 | -- |
| F2 – AHU-4 Motor Replacement | FIM | Capital Improvement | -- | -- | \$2,400 | -- |
| F3 – AHU-4 EHC Replacement | FIM | Capital Improvement | -- | -- | \$5,000 | -- |
| Totals | | | 167,823 | \$16,967 | \$88,790 | 5.2 |

*ROI calculations exclude capital improvement items, as they are intended more for facility improvement than for energy savings.

The cost and paybacks shown in the table above are estimates based on the information gathered during the auditing process. TLC utilized RSMMeans 2023, as well as engineering best practices, to estimate the cost of these suggested measures. Final pricing will vary based on contractors' estimation and final equipment selections. Final payback periods are also dependent on contractor pricing and the facility's negotiated utility price.

Chiller Optimization

General Description

This measure proposes to optimize the settings and sequences that govern the chiller operation. A chiller and its associated chilled water distribution system have a wide variety of key input parameters and

controls strategies that can greatly influence how it operates. Over time, adjustments are often made to chiller controls to either resolve a temporary problem, minimize maintenance requests from occupants, or other reasons. These adjustments can often result in the chilled water system operating in a less optimal way than was originally designed. A chilled water design typically considers different efficiencies at varying operating conditions, meaning a return to design operation can result in energy savings.

Site Specifics

During the on-site audits, it was observed that the chiller provides chilled water at temperatures between 41°F and 42°F. This is lower than the design leaving water temperature of 44°F from the as-built drawings. Operating a chiller at a lower leaving water temperature will cause the chiller to work harder and expend more energy in a less efficient manner. This measure proposes to adjust the chiller settings to provide 44°F water as originally designed. This is a setpoint change that TLC believes building operations should be able to provide as a no-cost change.

DX CRAC Unit Retrofit

General Description

This measure proposes replacing existing DX CRAC equipment, which is at or nearing the end of its predicted useful life. Direct expansion (DX) air conditioning equipment consists of a refrigerant loop, in which the refrigerant is compressed and expanded at different points of the loop to transfer thermal energy. Typically, a refrigerant coil is placed directly in the supply air stream, where the refrigerant absorbs thermal energy as it evaporates and expands. Thermal energy is rejected at a compressor, where the refrigerant is compressed and condenses, rejecting the heat that was removed from the supply air stream.




Figure 3: The Refrigeration Cycle

Over time, HVAC units degrade in operational efficiency as coil surfaces oxidize on the exterior and sometimes scale on the interior which reduces heat transfer efficiency. The moving mechanical components also wear, which further reduces the operational efficiency of the equipment. The new equipment will be installed in place of the existing equipment, including providing new refrigerant line sets for all split systems.

Advances in technology and improvements necessitated by energy code updates have led to DX equipment available today with far higher efficiencies than what was used in the past. Replacing the existing systems with new higher efficiency systems will reduce energy consumption and provide improved occupant comfort.

Site Specifics

The Liebert split system that serves the 2nd floor communications room was observed to be nearing the end of its expected useful life and in need of replacement. This measure proposes to replace the existing split system with a like-for-like replacement. As stated above, the newer system will be more efficient than the existing system and will result in slight energy savings.

CV to VAV

General Description

This measure proposes to convert an existing constant volume air handling unit (AHU-4) to be variable air volume (VAV) systems with a single zone. Existing constant volume (CV) air handlers provide constant airflow to the spaces whenever the fan is running. The zone temperatures in these spaces are controlled by varying the supply air temperature or cycling coils on and off. VAV systems allow the fan speed to be reduced for part load conditions, only providing the amount of air that is needed to meet the load. The modulating airflow, in conjunction with changing the supply air temperature, allows for tighter control of thermal comfort for changing space loads.

The air handling unit supply fan motor will be replaced with a premium efficiency inverter duty motor, with a new variable frequency drive (VFD) to vary the supply fan speed/airflow to control space temperature. Varying fan speed can greatly reduce the fan energy and make the system more efficient without sacrificing occupant comfort. The following graphic shows how varying load in the space will change the supply air temperature and fan speed.




Figure 4: Varying Temperature and Airflow

When applying this strategy, consideration will be taken to maintain high enough airflow to keep sufficient ventilation in all spaces, and enough air velocity to maintain proper throw from diffusers.

Site Specifics

The existing AHU-4 will be converted to VAV. During the audit, it was noted that the system is always in dehumidification mode due to a 99% return air humidity reading from a bad sensor. The chilled water valve was open 100% and the electric heat was calling for 100% heating. As the space was noted to be 67°F during the audit, it appears the electric heat is nonfunctional. In addition to converting the system to VAV as described above, the bad sensor and electric heat will be repaired or replaced to full functional condition.

AHU Controls

General Description

This measure proposes to install or update AHU controls. Over time, the control sequences for HVAC equipment such as air handling units will be modified from its original intent. It is also common for the building operation requirements to change, or for manual overrides to be put in place. These changes can result in HVAC systems consuming excess energy and not meeting their original design intent. By optimizing the controls, the HVAC systems can either be returned to their original design intent or can be optimized further than originally intended due to changes to the building operational needs.

Site Specifics

During the audit, it was observed that the VFDs for the outside air fans associated with AHU-1 through 3 were operating in hand at 100%. Further investigation indicated that the return air dampers for the associated AHUs were either removed, rusted, or otherwise rendered inoperable. The outside air fans were likely put into hand to compensate for the lack of return damper control, in order to over-pressurize the outside air duct and force adequate outside air into the AHUs.

While a test and balance report from August 2022 indicated that the outside air being provided was less than the design airflow, it also indicated that the OA fans were not operating. We are unable to confirm at this time, but the outside air fans may be providing excess outside air given their constant 100% operation. If that is the case, resolving the AHU controls issues described will also save energy from conditioning less outside air.

Controls Optimization

General Description

The scope for this ECM involves optimizing the building HVAC controls through one or multiple controls strategies. For this project, the controls strategy recommended would be occupancy scheduling with setback temperatures.

Consistent occupied and unoccupied temperature settings will be implemented based on the building type and their needs. Occupied schedules for the HVAC controls will be set up to dictate the hours when the building is considered occupied versus unoccupied. Whenever a building enters unoccupied mode, the building HVAC controls will utilize the unoccupied settings in lieu of the occupied settings.

Site Specifics

While the building overall is considered a 24/7 occupancy building, there are areas that are not occupied outside of regular office hours. These noncritical areas would be optimized with controls schedules based on the hours these areas are typically occupied. HVAC controls will be given setback temperature settings to use during unoccupied conditions. Operating portions of the building at setback temperatures will result in energy savings due to the HVAC systems not having to work as hard to condition these areas when unoccupied.

Lighting Improvements

General Description

This measure involves converting older style lighting fixtures, such as fluorescent and incandescent, to modern LED lighting fixtures and lamps. Unless a building has been built or renovated in the past few years, it is common to find extensive use of fluorescent and incandescent fixtures throughout the building. Fluorescent and incandescent lighting technologies are a product of their time and often remain without intentional replacement. Older lighting technologies require more wattage to produce the same amount of light as LED fixtures. This also results in a higher heat output from the lamps which raises HVAC cooling costs.

Existing fluorescent and incandescent lighting fixtures will be replaced/retrofitted with new LED lighting fixtures. This will greatly reduce the energy required to illuminate the building. Additionally, cooling systems will have to run less often to offset the heat generated by the lighting. There are several additional benefits to LED lighting technology. LED lighting has longer burn hour life, faster on/off response time, and easier dimming capabilities compared to fluorescent and incandescent technologies. Because LED light fixtures have longer burn hour life, this will reduce the material and time cost of replacing burned out lamps.

Site Specifics

The facility was observed to have predominantly linear fluorescent fixtures with T8 lamps. Existing non-LED lighting will be replaced with new LED lighting on a one-for-one basis. Existing lighting material waste will be disposed of according to local regulations.

Facility Improvement Measures

TLC identified additional Facility Improvement Measures (FIM) that do not provide energy savings but should be addressed. By implementing the recommended FIM, the facility will experience improved equipment reliability, increased thermal comfort for occupants, and be able to operate as originally designed.

DHW Retrofit

One out of the two gas-fired water heaters (GWH) were observed to be out of commission due to a bad firing mechanism. The other water heater is able to function but may be short on capacity at peak design conditions. The nonfunctional water heater should be repaired or replaced if deemed necessary. Having

both water heaters functional will allow for the full designed capacity, as well as provide partial redundancy in the event that one needs maintenance or repairs. This redundancy benefit is currently being seen with one of the units down.

Calculation Methodology – Spreadsheet System Models

Savings for this report were evaluated using spreadsheet building models for the lighting and HVAC systems. The methodologies used for each measure are described separately in this section. Industry Standard methods of evaluation were used and are detailed in this section. Additionally, assumptions made to calculate the energy savings are detailed.

Chiller Optimization

Savings for this measure have been based on a reduction in cooling energy due to more efficient chiller operation. The following table shows the major inputs used in the calculation of savings for this measure.

Table 6: Chiller Optimization Major Inputs

| Input Name | Bldg./Area Affected | Input Value | Basis of Input |
|-----------------------------------|---------------------|-----------------|---|
| Existing Chiller LWT | Air-Cooled Chiller | 41.5°F | Audit observations |
| Design Chiller LWT | Air-Cooled Chiller | 44.0°F | As-built drawings |
| Efficiency Penalty for LWT | Air-Cooled Chiller | 1.5% per degree | Engineering judgment, previous projects |

Calculations:

Savings for this measure were based on calculating the change in annual cooling energy based on a more efficient chiller. The existing annual cooling energy was calculated from the electric utility baseline as the sum of all the electrical consumption for each month exceeding the lowest month’s consumption. The following formula was used to calculate existing annual cooling energy.

$$\text{Existing Cooling kWh} = \text{Annual Total kWh} - (12 \times \text{Baseload Month kWh})$$

In the formula, the baseload month kWh was the consumption for the month with the lowest consumption in the baseline. The efficiency penalty percentage was calculated with the formula below.

$$\text{Efficiency Penalty} = (1 + 1.5\%)^{(LWT_{Design} - LWT_{Existing})}$$

The proposed cooling energy was then calculated with the following formula. The savings are the difference between the existing and proposed cooling energy.

$$\text{Proposed Cooling kWh} = \text{Existing Cooling kWh} \times \left(\frac{1}{\text{Efficiency Penalty}} \right)$$

DX Unit Retrofits

Savings for this measure have been based on an improvement in the efficiency of the DX equipment. The following table shows the major inputs used in the calculation of savings for this measure.

Table 7: DX Unit Retrofit Major Inputs

| Input Name | Bldg./Area Affected | Input Value | Basis of Input |
|----------------------------------|---------------------|---------------|---|
| CU-2 Rated Capacity | CU-2 | 2.8 tons | Manufacturer info |
| CU-2 Existing Efficiency | CU-2 | 12.79 SEER | Mfg. info and typical degradation for age |
| CU-2 Proposed Efficiency | CU-2 | 16.0 SEER | Engineering judgment |
| Effective Full Load Hours | CU-2 | 1,600 hr./yr. | Estimate based on project location |

Calculations:

Savings for this measure were based on calculating the energy consumption of the DX equipment with the existing and proposed efficiencies. The unit's energy consumption in kWh was calculated with the following formula.

$$\text{Energy Consumption} = \text{Tons} \times \left(\frac{12}{\text{SEER}} \right) \times \text{Effective Full Load Hours}$$

In the formula, the terms in the bracket yield efficiency in kW/ton.

CV to VAV

Savings for this measure have been based on a reduction in the power consumed by the AHU supply fan. The following table shows the major inputs used in the calculation of savings for this measure.

Table 8: CV to VAV Major Inputs

| Input Name | Bldg./Area Affected | Input Value | Basis of Input |
|---------------------------------|---------------------|-------------|---|
| Fan Motor HP | AHU-4 | 1.0 | As-built drawings |
| Annual Operating Hours | AHU-4 | 8,760 | Building schedule |
| Existing Fan Power Ratio | AHU-4 | 1.00 | No reduction, fan always at 100% power |
| Proposed Fan Power Ratio | AHU-4 | 0.28 | Estimated average condition of 60% flow |

Calculations:

Savings for this measure were based on calculating the annual fan energy with the existing and proposed fan power ratios. The fan's annual energy consumption in kWh was calculated with the following formula.

$$\text{Energy Consumption} = \text{Fan HP} \times 0.7457 \times \text{Hours} \times \text{Fan Power Ratio}$$

AHU Controls

Savings for this measure have been based on a reduction in the power consumed by the outside air fans associated with AHU-1 through 3. The following table shows the major inputs used in the calculation of savings for this measure.

Table 9: AHU Controls Major Inputs

| Input Name | Bldg./Area Affected | Input Value | Basis of Input |
|--------------------------|---------------------|-------------|---|
| Fan Motor HP | AHU-1 OA Fan | 3.0 | As-built drawings |
| Fan Motor HP | AHU-2 OA Fan | 1.5 | As-built drawings |
| Fan Motor HP | AHU-3 OA Fan | 1/3 | As-built drawings |
| Annual Operating Hours | AHU-1,2,3 OA Fan | 8,760 | Building schedule |
| Existing Fan Power Ratio | AHU-1,2,3 OA Fan | 1.00 | No reduction, fan always at 100% power |
| Proposed Fan Power Ratio | AHU-1,2,3 OA Fan | 0.28 | Estimated average condition of 60% flow |

Calculations:

Savings for this measure were based on calculating the annual fan energy with the existing and proposed fan power ratios. The fan's annual energy consumption in kWh was calculated with the following formula.

$$\text{Energy Consumption} = \text{Fan HP} \times 0.7457 \times \text{Hours} \times \text{Fan Power Ratio}$$

Controls Optimization

Savings for this measure have been based on a reduction in cooling energy due to setting back non-critical portions of the building that are not always occupied. The following table shows the major inputs used in the calculation of savings for this measure.

Table 10: Controls Optimization Major Inputs

| Input Name | Bldg./Area Affected | Input Value | Basis of Input |
|----------------------------|---------------------|-------------|----------------------|
| % Cooling Energy Reduction | Entire building | 1% | Engineering judgment |

Calculations:

Savings for this measure were based on calculating the annual cooling energy and saving a percentage of it. The existing annual cooling energy was calculated from the electric utility baseline as the sum of all the electrical consumption for each month exceeding the lowest month's consumption. The following formula was used to calculate existing annual cooling energy.

$$\text{Existing Cooling kWh} = \text{Annual Total kWh} - (12 \times \text{Baseload Month kWh})$$

Lighting Improvements

Savings for this measure have been based on a reduction in the lighting energy based on a reduction in lighting installed wattage. The following table shows the major inputs used in the calculation of savings for this measure.

Table 11: Lighting Improvements Major Inputs

| Input Name | Bldg./Area Affected | Input Value | Basis of Input |
|---------------------------------|---------------------|-------------|---------------------------------------|
| Building Area | Entire building | 36,535sf | Provided value |
| Existing Lighting Power Density | Entire building | 1.0 W/sf | Typical value for T8 lamps throughout |

| Input Name | Bldg./Area Affected | Input Value | Basis of Input |
|--|---------------------|-------------|--|
| Proposed Lighting Power Density | Entire building | 0.6 W/sf | Typical value for LED lamps throughout |
| Annual Burn Hours | Entire building | 8,760 | Building schedule |

Calculations:

Savings for this measure were comprised of energy savings. The energy savings were the difference in the existing and proposed kWh for all the lighting fixtures in the building. The energy usage in kWh for the building was calculated using the following formula.

$$Energy\ Usage = \frac{Building\ Area \times LPD \times Hours}{1,000}$$

Appendix A – Lighting Line by Line

The following table shows a list of design fixtures in the building. This is not a comprehensive list of all fixtures but details a good representation. This includes only permanent fixtures and does not include any construction lighting.

| FIXTURE SCHEDULE | | | | | | |
|------------------|--|----------------|-------|-------|----------------------|-----------------|
| TYPE | DESCRIPTION | TOTAL WATTS | LAMPS | | MOUNTING | |
| | | | NO. | WATTS | | |
| FA | MAIN LOBBY FIXTURE. EQUIP WITH PORCELAIN LAMP SOCKETS FOR 120V MEDIUM BASED LAMPS, MOTTLED BRASS FINISH, GOLD-WHITE SHADE GLASS. REJENATION MODEL C321 | 240 | 12 | 15 | CF1SEL/830/ MED/1 | PENDANT |
| FA1 | COMMUNITY ROOM FIXTURE. EQUIP WITH PORCELAIN LAMP HOLDERS FOR 120V MEDIUM BASED LAMPS, MOTTLED BRASS FINISH, GOLD-WHITE SHADE GLASS. REJENATION AMHERST MODEL C656 | 80 | 4 | 15 | CF1SEL/830/ MED/1 | PENDANT |
| FA2 | ENTRANCE LOBBY FIXTURE. EQUIP WITH PORCELAIN LAMP HOLDERS FOR 120V MEDIUM BASED LAMPS, MOTTLED BRASS FINISH, #174CE SHADE GLASS. REJENATION FRANKLIN MODEL C400 | 80 | 4 | 15 | CF1SEL/830/ MED/1 | PENDANT |
| FA3A | ENTRANCE CORRIDOR FIXTURE. EQUIP WITH PORCELAIN LAMP HOLDERS FOR 120V MEDIUM BASED LAMPS, MOTTLED BRASS FINISH, PORCELAIN GLASS SHADES, EXTEND OVERALL LENGTH TO 42 INCHES INCLUDING SHADES. REJENATION ARGYLE MODEL C246 | 40 | 2 | 15 | CF1SEL/830/ MED/1 | PENDANT |
| FA3B | ENTRANCE CORRIDOR FIXTURE. EQUIP WITH PORCELAIN LAMP HOLDERS FOR 120V MEDIUM BASED LAMPS, MOTTLED BRASS FINISH, PORCELAIN GLASS SHADES, EXTEND OVERALL LENGTH TO 36 INCHES INCLUDING SHADES. REJENATION ARGYLE MODEL C246 | 40 | 2 | 15 | CF1SEL/830/ MED/1 | PENDANT |
| FB | PENDANT INDIRECT-FLUORESCENT FIXTURE CONSISTING OF PERFORATED EXTRUDED ALUMINUM BRIZOM, SUPPORTED BY CRS STEEL CHASSIS WHICH ALSO SUPPORTS AN EXTRUDED SLOTTED ALUMINUM REFLECTOR, AN OPAL ACRYLIC DIFFUSER ABOVE THE LOWER HOUSING, LAMP HOLDERS AND 277V FUSED ELECTRONIC BALLAST FOR TWO F32T8 LAMPS PER FOUR FOOT SECTION. EACH EIGHT FOOT SECTION TO BE EQUIPPED WITH REGRESSED INTERMEDIATE CONNECTOR AND EACH RUN IS TO BE EQUIPPED WITH MATCHING REGRESSED END CAPS. FINISH EXPOSED METALLIC PARTS IN POWDER POLYESTER ENAMEL OF COLOR SELECTED BY ARCHITECT. LITHONIA "CLASSICAL" OR EQUAL, APPROVED BY ENGINEER | 70 | 2 | 32 | F032/ 835 | PENDANT |
| FBI | SIMILAR TO FIXTURE TYPE "FB" EXCEPT WALL MOUNTED. | 70 | 2 | 32 | F032/ 835 | WALL |
| FC | FLOURESCENT TROFFER, 2'x2' NOMINAL, FORMED CRS STEEL CHASSIS FINISHED IN HIGH REFLECTANCE BWE, WHITE FLAT SPRING-LOADED STEEL HINGE AND LATCH DOOR FRAME WITH INTEGRAL LIGHT TRAPS, VIRGIN PRISMATIC ACRYLIC DIFFUSER IN PATTERN 12/EQUIP WITH LAMP HOLDERS, AND 277 VOLT FUSED ELECTRONIC BALLAST FOR TWO F32T8 LAMPS. LITHONIA #23P SERIES, COLUMBIA #24 SERIES, DAYBRITE #2P3 SERIES | 70 | 2 | 32 | F031/ 835 | RECESSED |
| FD | FLOURESCENT TROFFER, 2'x4' NOMINAL, FORMED CRS STEEL CHASSIS FINISHED IN HIGH REFLECTANCE BWE, WHITE FLAT SPRING-LOADED STEEL HINGE AND LATCH DOOR FRAME WITH INTEGRAL LIGHT TRAPS, VIRGIN PRISMATIC ACRYLIC DIFFUSER IN PATTERN 12/EQUIP WITH LAMP HOLDERS, AND 277 VOLT FUSED ELECTRONIC BALLASTS (2/1) FOR THREE F32T8 LAMPS. LITHONIA #23P SERIES, COLUMBIA #24 SERIES, DAYBRITE #2P3 SERIES | 100 | 3 | 32 | F032/ 835 | RECESSED |
| FD1 | FLOURESCENT TROFFER, 1'x4' NOMINAL, FORMED CRS STEEL CHASSIS FINISHED IN HIGH REFLECTANCE BWE, WHITE FLAT SPRING-LOADED STEEL HINGE AND LATCH DOOR FRAME WITH INTEGRAL LIGHT TRAPS, VIRGIN PRISMATIC ACRYLIC DIFFUSER IN PATTERN 12 AND GASKETING FOR DAMP LOCATION LABEL. EQUIP WITH LAMP HOLDERS, AND 277 VOLT FUSED ELECTRONIC BALLAST FOR TWO F32T8 LAMPS. LITHONIA #23P SERIES, COLUMBIA #24 SERIES, DAYBRITE #2P3 SERIES | 70 | 2 | 32 | F032/ 835 | RECESSED |
| FE | FLOURESCENT TROFFER, 1'x4' NOMINAL, FORMED CRS STEEL CHASSIS FINISHED IN HIGH REFLECTANCE BWE, WHITE FLAT SPRING-LOADED STEEL HINGE AND LATCH DOOR FRAME WITH INTEGRAL LIGHT TRAPS, VIRGIN PRISMATIC ACRYLIC DIFFUSER IN PATTERN 12 AND GASKETING FOR DAMP LOCATION LABEL. EQUIP WITH LAMP HOLDERS, AND 277 VOLT FUSED ELECTRONIC BALLAST FOR TWO F32T8 LAMPS. LITHONIA #23P SERIES, COLUMBIA #24 SERIES, DAYBRITE #2P3 SERIES | 70 | 2 | 32 | F032/ 835 | RECESSED |
| FF | NET LOCATION INDUSTRIAL FLOURESCENT FIXTURE, 10'x4' NOMINAL, FORMED CRS STEEL BODY FINISHED IN HIGH REFLECTANCE BWE, MOLDED HIGH-IMPACT ACRYLIC DIFFUSER SECURED BY CORROSION-RESISTANT FASTENERS. EQUIP WITH LAMP HOLDERS AND 277 VOLT FUSED ELECTRONIC BALLAST FOR TWO F32T8 LAMPS. LITHONIA #JWSH SERIES, COLUMBIA #JLH SERIES, DAYBRITE # JVO SERIES | 70 | 2 | 32 | F032/ 835 | SURFACE |
| FG | SURFACE MOUNTED SECURITY FLOURESCENT FIXTURE OF WELDED 16GA COLD ROLLED STEEL WITH SMOOTH GRIND JOINTS MOUNTED ON A COLD ROLLED STEEL BRACKET PLATE, 20 INCHES WIDE BY 48 INCHES LONG BY 5 INCHES DEEP, THREE APERTURES FOR COMPOSITE DIFFUSERS CONSISTING OF PRISMATIC 0.156" POLYCARBONATE INNER LENS WITH 0.250" CLEAR SMOOTH POLYCARBONATE OUTER DIFFUSER SECURED IN A STEEL FRAME. ACCESS ONLY BY TORX HEAD REMOVING FASTENERS. EQUIP WITH 277 VOLT FUSED ELECTRONIC BALLASTS FOR INDIVIDUAL OPERATION OF TWO F32T8 LAMPS, ONE F32T8 LAMP AND ONE 9W CFL NIGHT LIGHT. FINISH EXPOSED METALLIC PARTS IN WHITE POWDER POLYESTER ENAMEL OVER MPFS. RECOMMENDED PRE-TREATMENT, KENALL "MIGHTY MAC" SERIES, MORLITE "SUPERMAC" SERIES, NEW STAR "SUNMS" SERIES | 100 | 3 | 32 | F032/ 835 | SURFACE |
| FH | STANDARD COMMERCIAL STRIP FLOURESCENT FIXTURE, FOUR FOOT WHITE PAINTED STEEL CHASSIS WITH LAMP HOLDERS AND 277V FUSED ELECTRONIC BALLAST FOR TWO F32T8 LAMPS. COLUMBIA "CS" SERIES, CORNER LITONIA "CS" SERIES | 70 | 2 | 32 | F032/ 835 | SURFACE |
| FJ | COMPACT FLOURESCENT VERTICAL DOWNLIGHT, 8" NOMINAL APERTURE, SEMI-SPECULAR CLEAR ALZAK REFLECTOR, RECESSED FLAT DOOR WITH FLAT PRESSEL LENS, FINED DIE-CAST ALUMINUM HEAT SINK, THROUGH WIRE JUNCTION BOX ACCESSIBLE FROM BELOW CEILING, 26" MOUNTING BARS. EQUIP WITH LAMP HOLDER AND FUSED 277 VOLT ELECTRONIC BALLAST FOR ONE 32TRT LAMP. LABEL FOR NET LOCATIONS. LITHONIA #JGVY SERIES, PRESCLUTE #PBX SERIES, CAPRI #JCB SERIES | 40 | 1 | 32 | 32W TRT | RECESSED |
| FK | COMPACT FLOURESCENT VERTICAL DOWNLIGHT, 8" NOMINAL APERTURE, SEMI-SPECULAR CLEAR ALZAK REFLECTOR SELF FLANGED IN PAINTED WHITE, FINED DIE-CAST ALUMINUM HEAT SINK, THROUGH WIRE JUNCTION BOX ACCESSIBLE FROM BELOW CEILING, 26" MOUNTING BARS. EQUIP WITH LAMP HOLDER AND FUSED 277 VOLT ELECTRONIC BALLAST FOR ONE 42TRT LAMP. LITHONIA #JGVY SERIES, PRESCLUTE #PBX SERIES, CAPRI #JCB SERIES | 50 | 1 | 42 | 42W TRT | RECESSED |
| FL | SQUARE COMPACT FLOURESCENT RECESSED FIXTURE, 11" NOMINAL SQUARE OPENING, CLEAR SEMI-SPECULAR ALZAK UPPER REFLECTOR, FLUSH DIE-CAST ALUMINUM DOOR FINISHED IN BWE AND GASKETED FLANGE, THROUGH WIRE JUNCTION BOX ACCESSIBLE FROM BELOW CEILING, 26" MOUNTING BARS. EQUIP WITH LAMP HOLDERS AND FUSED 277 VOLT ELECTRONIC BALLAST FOR TWO F42TRT LAMPS. NET LOCATION LABELED. LITHONIA #JAF SERIES, PRESCLUTE #PBX SERIES, CAPRI #JCB SERIES | 100 | 2 | 42 | 42W TRT | RECESSED |
| FL1 | SIMILAR TO TYPE "FL" AND OF THE SAME MANUFACTURER, EXCEPT EQUIPPED WITH DIMMING BALLAST PROVIDING DIMMING TO ONE PERCENT OF THE OUTPUT AND COMPATIBLE WITH PROVIDED WALL BOX DIMMER. | 100 | 2 | 42 | 42W TRT | RECESSED |
| FM | WALL MOUNTED UP-DOWN FLOURESCENT FIXTURE CONSISTING OF STEEL CHASSIS MOUNTING BLACK POWDER POLYESTER FINISHED EXTRUDED ALUMINUM BODY, INJECTION MOLDED CLEAR PRISMATIC BASKET DIFFUSER WITH PYRAMID PRISMS ON BOTTOM AND LINEAR PRISMS ON ENDS AND SIDES, PRISMATIC ACRYLIC UPPER DIFFUSER FOR UP LIGHT, LAMP HOLDERS AND FUSED 277 VOLT ELECTRONIC BALLAST FOR TWO F32T8 LAMPS. DAYBRITE "AZTEC" SERIES, METALUX "BUI" SERIES, OR EQUAL APPROVED BY ENGINEER | 70 | 2 | 32 | F032/ 835 | WALL |
| FMI | SIMILAR TO FIXTURE TYPE "FM" AND OF SAME MANUFACTURER EXCEPT EQUIPPED WITH LAMP SEPARATOR, SWITCHED NIGHT LIGHT (9W CFL) AND FULL SWITCH FOR OTHER LAMPS. | 70 | 2 | 32 | F032/ 835 | WALL |
| FN | FLOURESCENT WALL PACK, POLYCARBONATE BODY ON STEEL MOUNTING PLATE, INJECTION MOLDED POLYCARBONATE PRISMATIC DIFFUSER SEALED AND GASKETED TO BODY, EQUIP WITH 277V FUSED LOW TEMPERATURE BALLAST AND LAMP HOLDER FOR ONE 42W TRT FLOURESCENT LAMP. LITHONIA # TNL SERIES, GENERAL ELECTRIC #NM SERIES | 50 | 1 | 42 | 42W TRT | RECESSED |
| FO | FLOURESCENT TROFFER, 2'x4' NOMINAL, FORMED CRS STEEL CHASSIS FINISHED IN HIGH REFLECTANCE BWE WITH INDIVIDUAL LAMP COMPARTMENTS WHEN ASSEMBLED WITH LOUVER, FLOATING BLACK RECAL METER CUT ALUMINUM DOOR FRAME WITH INTEGRAL LIGHT TRAPS HOLDING A NOMINAL THREE INCH DEEP SEMI-SPECULAR LOW REFLECTANT PARABOLIC LOUVER WITH 18 CELLS. EQUIP WITH LAMP HOLDERS, AND 277 VOLT FUSED ELECTRONIC BALLASTS (2/1) FOR THREE F32T8 LAMPS. MFR.: LITHONIA #2PMS SERIES, COLUMBIA #224 SERIES, DAYBRITE #2U SERIES | 100 | 3 | 32 | FBO 32/ 835 | RECESSED |
| FP | PARABOLIC FLOURESCENT TROFFER, 2'x2' NOMINAL, FORMED CRS CHASSIS FINISHED IN HIGH REFLECTANCE WHITE POLYESTER SPRING COAT; BLACK, REGRESSED FLOATING, SPRING-LOADED, ALUMINUM, MITERED CORNER, HINGE AND SPRING LATCH, DOOR FRAME WITH INTEGRAL LIGHT TRAPS; 1-1/2" x 1-1/2" x 4" ALUMINUM WHITE PAINTED LOUVER; EQUIP CHASSIS WITH LAMP HOLDERS AND 277 VAC FUSED ENCAPSULATED AND POTTED ELECTRONIC BALLAST FOR TWO F31T8S (1-95" LED) LAMPS. MFR.: LITHONIA "2PMS" SERIES, DAYBRITE "2P3" SERIES, COLUMBIA "Y4" SERIES | 70 | 2 | 31 | FBO 31/ 835 | RECESSED |
| FP1 | SIMILAR TO TYPE "FP" AND OF SAME MANUFACTURER, EXCEPT EQUIPPED WITH TWO ONE LAMP BALLASTS FOR SPLIT CIRCUITING. | 70 | 2 | 31 | FBO 31/ 835 | RECESSED |
| FR | FLOURESCENT DIRECT/INDIRECT GRID TROFFER, 2'x4' NOMINAL, FORMED CRS STEEL CHASSIS FINISHED IN HIGH REFLECTANCE BWE, WHITE POLYESTER REFLECTORS, PERFORATED METAL BRIFERER FINISHED IN WHITE, EQUIP WITH LAMP HOLDERS, AND 277 VOLT FUSED ELECTRONIC DIMMING BALLAST FOR ONE F32T8 LAMP AND ONE TWO LAMP 277 VOLT FUSED ELECTRONIC BALLAST FOR TWO F32T8 LAMPS, DIMMING BALLAST RATED FOR ONE PERCENT MINIMUM OUTPUT AND COMPATIBLE WITH THE WALL BOX DIMMER CONTROLLING. MFR.: LITHONIA "AVANTIE" SERIES, COLUMBIA "STR" SERIES, DAYBRITE "AROSQ" SERIES | 100 | 3 | 32 | FBO 32/ 835 | RECESSED |
| FRI | SIMILAR TO TYPE "FR" AND OF SAME MANUFACTURE EXCEPT ALL THREE LAMPS EQUIPPED WITH FUSED 277 VOLT ELECTRONIC DIMMING BALLASTS FOR ALL THREE LAMPS. | 100 | 3 | 32 | FBO 32/ 835 | RECESSED |
| FT | FLOURESCENT UNDERCOUNTER FIXTURE CONSISTING OF THREE FOOT SOLID FRONT, LOW PROFILE METAL HOUSING FINISHED IN GLOSS-WHITE ENAMEL, ACRYLIC PRISMATIC DIFFUSER, EQUIP WITH LAMP HOLDERS, AND 277 VOLT FUSED ELECTRONIC BALLAST FOR ONE F25T8 LAMP. MFR.: LITHONIA "JUCS" SERIES OR APPROVED SUBSTITUTION BY ENGINEER | 35 | 1 | 25 | F0 25/ 855 | SURFACE |
| FU | SURFACE WALL MOUNTED FLOURESCENT FIXTURE CONSISTING OF TRAPEZOIDAL DIE CAST ALUMINUM BODY FINISHED IN BLACK POWDER COATED POLYESTER, RECTANGULAR PRISMATIC PRISMATIC TEMPERED GLASS LENS, TOP AND BOTTOM, WITH SMOOTH EXTERIOR AND EQUIPPED WITH NEOPRENE GASKET BETWEEN LENS AND BEZEL, CAST ALUMINUM BEZEL FINISHED IN POWDER COAT POLYESTER TO MATCH HOUSING, SECURED TO HOUSING BY TORX "S" SCREWS AND EQUIPPED WITH GLOUED CELL NEOPRENE GASKET BETWEEN HOUSING AND BEZEL, EQUIP WITH INTERNAL REFLECTORS, FUSED 277VAC/LOW TEMPERATURE ELECTRONIC BALLAST FOR TWO 26W CFL LAMPS. MFR.: HERELLE "26W SERIES" OR APPROVED EQUAL | 60 | 2 | 28 | CF2601/ E/N/835 | SURFACE WALL |

Appendix B – Mechanical Equipment

The following table shows a listing of all recorded major equipment in the building.

| Building | Type | Equip | Location Served | Tag | Qty | Capacity | Units | Make | Model | Serial Number | Year |
|---------------|-----------------------|--------------------|------------------|-------|-----|----------|-------|-----------|---|---------------|------|
| Public Safety | Air Handling Unit | AHU | First Floor | AHU-1 | 1 | 110.9 | Tons | Trane | MCCA066G AZOABC000 M0 | K02G16670A | 2002 |
| Public Safety | Air Handling Unit | AHU | Second Floor | AHU-2 | 1 | 76.0 | Tons | Trane | MCCA050B BK0C0DA | K02G16674A | 2002 |
| Public Safety | Air Handling Unit | AHU | Second Floor | AHU-3 | 1 | 35.0 | Tons | Trane | MCCB025N 0A000 | K02H18932A | 2002 |
| Public Safety | Air Handling Unit | AHU | Vehicle Evidence | AHU-4 | 1 | 5.39 | Tons | Trane | | | |
| Public Safety | Outdoor Air Fan | OAF | AHU-1 OA | OAF-1 | 1 | | kWh | Trane | | | |
| Public Safety | Outdoor Air Fan | OAF | AHU-2 OA | OAF-2 | 1 | 23409.0 | kWh | Greenheck | RSF-100-15-X | 21112107 | |
| Public Safety | Outdoor Air Fan | OAF | AHU-3 OA | OAF-3 | 1 | 10710.0 | kWh | Greenheck | RSF-100-3-X | 21112131 | |
| Public Safety | Chiller | Air Cooled Chiller | All Areas | CH-1 | 1 | 200.0 | Tons | Trane | RTAC 2004 U1DH UAFR L1TY NN5T A10A N0EX N | U17B07220 | 2017 |
| Public Safety | Pumps | Pumps | Chiller | P-1 | 1 | 25.0 | HP | Armstrong | 4030 | 466831 | |
| Public Safety | Pumps | Pumps | Chiller | P-2 | 1 | 25.0 | HP | Armstrong | 4030 | 466832 | |
| Public Safety | Air Conditioning Unit | AC | 1st Floor Com | AC-1 | 1 | 1/2 | HP | | | | |

Public Safety Building – ASHRAE Level 2 Audit

| | | | | | | | | | | | |
|---------------|-----------------------|----------------------|---------------------------|---------|---|-------|-------|-----------|------------------|------------|------|
| Public Safety | Air Conditioning Unit | AC | 2nd Floor Com | AC-2 | 1 | 1/2 | HP | Liebert | MMD36EA HEDF | 0244N70291 | 2002 |
| Public Safety | Air Conditioning Unit | AC | Com Center | AC-3 | 1 | 2.00 | HP | Liebert | VH125AHA AEI | 529890-001 | 2002 |
| Public Safety | Air Conditioning Unit | AC | Tele Switch | AC-4 | 1 | 1.50 | HP | Trane | TEM4A0B3 65315BA | 203956H73V | 2002 |
| Public Safety | Condensing Unit | Air Cooled Condenser | 1st Floor Com | CU-1 | 1 | 2.8 | To ns | Liebert | | | |
| Public Safety | Condensing Unit | Air Cooled Condenser | 2nd Floor Com | CU-2 | 1 | 2.8 | To ns | Liebert | DCDF165-A | C14K2F2629 | 2014 |
| Public Safety | Condensing Unit | Air Cooled Condenser | Com Center | CU-3 | 1 | 10.0 | To ns | Libert | | | |
| Public Safety | Condensing Unit | Air Cooled Condenser | Tele Switch | CU-4 | 1 | 4.9 | To ns | Trane | 4TTR4036L 1000AA | 203910263F | 2002 |
| Public Safety | Exhaust Fans | EF | Crew Area Toilets | EF-1-1 | 1 | [175] | HP | Greenheck | | | 2002 |
| Public Safety | Exhaust Fans | EF | Crew Area Janitor | EF-1-2 | 1 | [100] | HP | Greenheck | | | 2002 |
| Public Safety | Exhaust Fans | EF | First Floor Lobby Toilets | EF-1-3 | 1 | 1/3 | HP | Greenheck | CSP-264 | | 2002 |
| Public Safety | Exhaust Fans | EF | Crew Area Toilets | EF-1-4 | 1 | [150] | HP | Greenheck | | | 2002 |
| Public Safety | Exhaust Fans | EF | Elev Equipment | EF-1-5 | 1 | [150] | HP | Greenheck | | | 2002 |
| Public Safety | Exhaust Fans | EF | First Floor Toilets | EF-1-6 | 1 | 1/3 | HP | Greenheck | CSF-264 | | 2002 |
| Public Safety | Exhaust Fans | EF | Apparatus Bay | EF-1-7 | 1 | 3 | HP | Greenheck | GB-330-30-X | 02H25627 | 2002 |
| Public Safety | Exhaust Fans | EF | Paper Shredder | EF-1-8 | 1 | 1/3 | HP | Greenheck | CSP-264 | | 2002 |
| Public Safety | Exhaust Fans | EF | Hose Storage | EF-1-9 | 1 | 1/6 | HP | Greenheck | | | 2002 |
| Public Safety | Exhaust Fans | EF | Bunker Gear | EF-1-10 | 1 | 1/8 | HP | Greenheck | | | 2002 |


Public Safety Building – ASHRAE Level 2 Audit

| | | | | | | | | | | |
|---------------|--------------|----|------------------------|---------|---|-------|----|--------------|---------------------|------|
| Public Safety | Exhaust Fans | EF | Maintenance/Decon Room | EF-1-11 | 1 | [350] | HP | Greenheck | CSP-264 | 2002 |
| Public Safety | Exhaust Fans | EF | EMS Storage | EF-1-12 | 1 | 1/3 | HP | Greenheck | | 2002 |
| Public Safety | Exhaust Fans | EF | Compressor/Scba Room | EF-1-13 | 1 | [250] | HP | Greenheck | | 2002 |
| Public Safety | Exhaust Fans | EF | Kitchen Hood | EF-1-14 | 1 | 1/4 | HP | Captive Aire | DU50HPA | 2002 |
| Public Safety | Exhaust Fans | EF | Evidence Toilet | EF-1-15 | 1 | [100] | HP | Greenheck | | 2002 |
| Public Safety | Exhaust Fans | EF | Evidence Storage | EF-1-16 | 1 | 1/3 | HP | Greenheck | | 2002 |
| Public Safety | Exhaust Fans | EF | Cell Area | EF-1-17 | 1 | 1/3 | HP | Greenheck | BSQ-120-3 | 2002 |
| Public Safety | Exhaust Fans | EF | Locker Rooms | EF-1-18 | 1 | 1/4 | HP | Greenheck | BSQ-160-4 | 2002 |
| Public Safety | Exhaust Fans | EF | Haz Mat Storage | EF-1-19 | 1 | [100] | HP | Greenheck | | 2002 |
| Public Safety | Exhaust Fans | EF | Ammo Room | EF-1-20 | 1 | [200] | HP | Greenheck | | 2002 |
| Public Safety | Exhaust Fans | EF | Elev Equipment | EF-1-21 | 1 | [150] | HP | Greenheck | TEM4A0B3 65315BA | 2002 |
| Public Safety | Exhaust Fans | EF | Blood Drying | EF-1-22 | 1 | [100] | HP | Greenheck | | 2002 |
| Public Safety | Exhaust Fans | EF | K-9 Area | EF-1-23 | 1 | 1/8 | HP | Greenheck | | 2002 |
| Public Safety | Exhaust Fans | EF | Decon Room | EF-1-24 | 1 | 1/25 | HP | Greenheck | | 2002 |
| Public Safety | Exhaust Fans | EF | Haz Evidence Storage | EF-1-25 | 1 | 1/20 | HP | Greenheck | | 2002 |
| Public Safety | Exhaust Fans | EF | Armory | EF-1-26 | 1 | [150] | HP | Greenheck | | 2002 |
| Public Safety | Exhaust Fans | EF | Vehicles | EF-1-27 | 1 | 3/4 | HP | Greenheck | GB-180-7 | 2002 |
| Public Safety | Exhaust Fans | EF | 2nd Floor Toileta | EF-2-1 | 1 | [100] | HP | Greenheck | | 2002 |

Public Safety Building – ASHRAE Level 2 Audit

| | | | | | | | | | | | |
|---------------|-----------------|------------------------------|-------------------|--------|---|----------|-------|--------------|-------------|---------------|------|
| Public Safety | Exhaust Fans | EF | Drug | EF-2-2 | 1 | 1/20 | HP | Greenheck | G-065-D-X | 02H25695 | 2002 |
| Public Safety | Exhaust Fans | EF | 2nd Floor Toilets | EF-2-3 | 1 | [100] | HP | Greenheck | | | 2002 |
| Public Safety | Exhaust Fans | EF | 2nd Floor Toilets | EF-2-4 | 1 | 1/6 | HP | Greenheck | | | 2002 |
| Public Safety | Exhaust Fans | EF | 2nd Floor Toilets | EF-2-5 | 1 | 1/8 | HP | Greenheck | | | 2002 |
| Public Safety | Exhaust Fans | EF | 2nd Floor Toilets | EF-2-6 | 1 | 1/3 | HP | Greenheck | G-160-B | 02H25780 | 2002 |
| Public Safety | Exhaust Fans | EF | 2nd Floor Toilets | EF-2-7 | 1 | 1/20 | HP | Greenheck | | | 2002 |
| Public Safety | Exhaust Fans | EF | 2nd Floor Toilets | EF-2-8 | 1 | 1/20 | HP | Greenheck | | | 2002 |
| Public Safety | Exhaust Fans | EF | 2nd Floor Toilets | EF-2-9 | 1 | 1/25 | HP | Greenheck | G-095-D-X | 02H25746 | 2002 |
| Public Safety | SF | Supply Fan | Kitchen Hood | SF-1 | 1 | 1/4 | HP | Captive Aire | INLINEI-G10 | | 2002 |
| Public Safety | Water Heater | Natural Gas Water Heater | | GW H-1 | 1 | 130000.0 | BT U | AO Smith | BTH-150 300 | 1717105909390 | 2017 |
| Public Safety | Water Heater | Natural Gas Water Heater | | GW H-2 | 1 | 150000.0 | BT U | RUUD | GHE80ES-130 | A341708584 | 2017 |
| Public Safety | Water Heater | Natural Gas Water Heater | | GW H-3 | 1 | 130000.0 | BT U | AO Smith | | | 2017 |
| Public Safety | Water Heater | Electric Water Heater | | EW H-1 | 1 | | | AO Smith | | | 2002 |
| Public Safety | Pump | Circulator Pump | GWH-1 | RCP-1 | 1 | | | Taco | 0011 | | 2002 |
| Public Safety | Pump | Circulator Pump | GWH-2 | RCP-2 | 1 | | | Taco | 0010 | | 2002 |
| Public Safety | Condensing Unit | Split System Condensing Unit | | | 1 | 3 | To ns | Daikin | RK36NMVJ UA | E002005 | 2020 |
| Public Safety | Condensing Unit | Split System Condensing Unit | | | 1 | 4 | To ns | Daikin | RK36NMVJ UA | E002197 | 2020 |

Appendix C – Site Walkthrough Photos



C-1: Entry/Reception Lighting (1)



C-2: Entry/Reception Lighting (2)



C-3: Conference Room Thermostat



C-4: AHU-2 Outside Air Fan VFD at 100%



C-5: AHU-3 Supply Fan



C-6: AHU-3 Supply Fan Motor



C-7: Emerson CRAC Condensing Unit



C-8: Trane Rooftop Condensing Unit



C-9: Rooftop Exhaust Fan (1)




C-10: Rooftop Outside Air Fan



C-11: Rooftop Exhaust Fan (2)



C-12: Air-Cooled Chiller CH-1



C-13: CH-1 Nameplate



C-14: CH-1 Refrigeration Components



C-15: Air Handling Unit AHU-1



C-16: Outside Air Fan OAF-1



C-17: Chilled Water Pump



C-18: Chilled Water Pump Nameplate



C-19: Air Handling Unit AHU-4



C-20: AHU-4 Chilled Water Coil Condition




C-21: AHU-4 Heating Coil Condition



C-22: Gas-Fired Water Heater (1)



C-23: Gas-Fired Water Heater (2)



C-24: Water Heater Setpoint Information

The screenshot displays the Tracer Ensemble software interface for a chiller unit. The browser address bar shows the URL: `cityofwinterpark.ensemblecloud.com/TracerEnsemble/Graphics/en-US/WPSAFETY/chiller-1%20graphic/chiller-1%20graphic.html?BuildingId=1&Referr...`. The user is identified as Leif Bouffard.

Chiller-1 Graphic

GRAPHIC | **STATUS**

RTAA Chiller 130 to 213 TOR KTAAR

Enabled: Auto
 Run Mode: Occupied
 Operating Mode: Run: Normal
 Alarm Present: None Detected

Buttons:

Chilled Water Status:
 Chilled Water Flow Status: Yes
 Chilled Water Flow Request: Yes

Chilled Water Temperatures:
 Chilled Water Entering Temp: 43.5 Deg
 Chilled Water Leaving Temp: 41.3 Deg
 Chilled Water Delta Temp: 2.2 Deg

Chilled Water Setpoint:
 Active Chilled Water Setpoint: 42.0 42.0 Deg
 Current Draw: 25 %RLA

Refrigerant Pressures:
 Evaporator Pressure CKT-1: 32.0 Psi
 Evaporator Pressure CKT-2: 37.3 Psi
 Condensor Pressure CKT-1: 109.8 Psi
 Condensor Pressure CKT-2: 94.1 Psi
 Suction Pressure CKT-1: 36.7 Psi
 Suction Pressure CKT-2: 42.4 Psi

Refrigerant Temperatures:
 Evaporator Temp CKT-1: 36.7 Deg
 Evaporator Temp CKT-2: 42.4 Deg
 Condensor Temp CKT-1: 92.8 Deg
 Condensor Temp CKT-2: 84.4 Deg

Chilled Water Pumps Status and Alarms:
 Chilled Water Pump-1 Status: Running Normal
 Chilled Water Pump-2 Status: Stopped Normal

Chiller Diagnostics:
 Automatic Reset: None Detected
 Automatic Reset CKT-1: None Detected
 Automatic Reset CKT-2: None Detected

The interface also features a 3D model of the chiller unit on the right side. A sidebar on the left shows a navigation tree for 'Winter Park Public Sa' with categories like Spaces, Chillers, Air Handlers, and Systems. The bottom of the screen shows a Windows taskbar with the date 12/8/2022 and time 1:28 PM.

C-25: BAS Chiller Summary

Public Safety Building – ASHRAE Level 2 Audit

Chilled Water System Summary Data:

| Parameter | Value |
|-----------------------|-------|
| Ahu 1 Valve% | 27.5 |
| Ahu 2 Valve% | 53.4 |
| Ahu 3 Valve% | 100.0 |
| Ahu 4 Valve% | 100.0 |
| CHWS AVG Valve% | 67.8 |
| Delta Temp | 2.3 |
| DP Ahu-2 | 4.7 |
| Override CHW Setpoint | 42.0 |
| Override DP Setpoint | 4.0 |

Additional interface elements include: Outside Temp: 81.0 Deg, Rotates Pumps: Off, Lead Pump Is: 1.0, Pump-1 Speed: 75.0%, Pump-2 Speed: 0.0%, and a navigation menu with options like 'Main Page', '1st Floor B Side (North)', '1st Floor A Side (South)', '2nd Floor B Side (North)', '2nd Floor A Side (South)', 'VAVs 1st Floor B (North)', 'VAVs 1st Floor A (South)', 'VAVs 2nd Floor B (North)', and 'VAVs 2nd Floor A (South)'.

C-26: BAS Chilled Water System Summary

The screenshot displays the Tracer Ensemble web interface for the Public Safety Building. The main view is the 'AhU-1 Graphic', which includes a 3D model of the air handling unit and associated components. The interface is divided into several sections:

- Navigation and Search:** Includes a search bar, a tree view on the left for navigating through building systems (Spaces, Chillers, Air Handlers, Systems, Ahu-3 Graphic, Main Graphic), and a 'Main Page' button.
- System Selection:** A list of systems to monitor, including:
 - 1st Floor B Side (North)
 - 1st Floor A Side (South)
 - 2nd Floor B Side (North)
 - 2nd Floor A Side (South)
 - VAVs 1st Floor B (North)
 - VAVs 1st Floor A (South)
 - VAVs 2nd Floor B (North)
 - VAVs 2nd Floor A (South)
 - Chilled Water System
 - Chiller-1
 - Exhaust Fans
- Area Vav Information:**

| | |
|---------------|-------------|
| Total Flow: | 13,569.7cfm |
| Max Temp: | 72.1 F |
| Min Temp: | 64.4 F |
| Avg. Temp: | 68.8 F |
| Cooling Req: | 3.0 |
| Heating Req: | 8.0 |
| Failed Boxes: | 1.0 |
| Max Position: | 100.0 |
- Operational Data:**
 - Occupancy Mode: Occupy
 - OSA Fan VFD: Running (99.6%)
 - OSA Damper: 100.0%
 - Valve Output: 20.1%
 - Return Temp: 69.5 Deg
 - Return Humidity: 58.3 Deg
 - Return C02: 450.3 PPM
 - Fan Speed: 81.1%
 - Fan Status: Running
 - Fan Alarm: Normal
 - VFD Speed: 28.0%
 - Room Pressure: 0.0000 lwc
 - Room Setpoint: -0.0100 lwc
- User Adjustable Setpoints:**

| | | |
|--------------------------|----------|------------------|
| Supply Air Setpoint | 57.9 Deg | Override Control |
| Static Pressure Setpoint | 2.0 lwc | Override Control |
| Humidity Setpoint | 60.0 % | Override Control |
| Supply Temp | 58.6 Deg | |
| Static Pressure | 2.10 lwc | |
- Weather and System Status:**
 - Weather: 80°F Sunny
 - System Status: Building

C-27: BAS AHU Graphic

Tracer Ensemble
 cityofwinterpark.ensemblecloud.com/TracerEnsemble/Graphics/en-US/WPSAFETY/ahu-4%20graphic/ahu-4%20graphic.html?BuildingId=1&ReferralGra...
 Leif Bouffard

Winter Park Public Safety

Search

Ahu-4 Graphic Main Page

GRAPHIC STATUS

1st Floor B Side (North) **Main Page** **Serves First Floor- Police- p/o B Side** **User Adjustable Setpoints**

| Parameter | Value | Unit | Control |
|----------------------------|----------|------|----------------------------|
| Space Temperature | 67.3 | Deg | Occupancy Mode |
| Return Temperature | 68.4 | Deg | Control Mode |
| Local Setpoint | --- | Deg | Local Setpoint Enable |
| Return Humidity | 99.3 | % | Supply Air Setpoint |
| Humidity Setpoint | --- | % | Humidity Setpoint |
| Heat/Cool Deadband | --- | Deg | OSA Deg for Damper to 100% |
| OSA Deg for Damper to 100% | --- | Deg | Space Temperature Setpoint |
| Space Temperature Setpoint | 72.0 | Deg | |
| Mixed Air Temperature | --- | Deg | |
| Supply Temperature | 55.4 | Deg | |
| Static Pressure | --- | hwc | |
| OSA Damper | 20.0 | % | |
| Valve Output | 100.0 | % | |
| CHWW Control Source | Humidity | | |
| Fan Status | Running | | |
| Fan Alarm | --- | | |
| EDH Reheat | 100.0 | % | |

80°F Sunny 1:52 PM 12/8/2022

C-28: BAS AHU-4 Graphic

