



fairbanks AveNews



The City of Winter Park's construction update for Fairbanks Avenue.

Project update

August 9, 2013

- Performed pneumatic leak tests on all gravity sewer pipe-everything passed.
- Performed vacuum leak tests on all sewer manholes-all of them passed.
- Replaced concrete driveway to Wymore lift station.
- Replaced brick driveway just south of Wymore Road lift station with 6" concrete driveway.
- Continued with installation of 3M locate balls on Wymore force main.
- Performed electronic depth locates on "traceable" HDPE force main.
- Placed 1.5" of structural course asphalt over gravity sewer/force main trench in Fairbanks Avenue median.
- Milled all four thru lanes 3" depth and placed 1.5" structural course asphalt from Cherry Street to 425' east.
- Milled and overlaid with 1.5" friction course asphalt from U.S. Highway 17-92 to Ohio Street.

Stay informed

- Updates to the construction schedule will be posted regularly on the Fairbanks web page cityofwinterpark.org/fairbanks.
- To receive **email updates** follow these steps:
 - Visit the Fairbanks web page cityofwinterpark.org/fairbanks
 - Click on "*Sign up here for email updates*" button to enter your email information
 - Select the "*Fairbanks AveNews*" subscription

fairbanks@cityofwinterpark.org ■ 407.643.1655
cityofwinterpark.org/Fairbanks

